

# ABB

## HS/S4.2.1

Brightness sensor


2CDG120044R0011

Installation and  
operating instructions



309597 01

GB



HS/S4.2.1

## Contents

Basic safety instructions	3
Display and keys	4
Connection/installation	5
Bus connection, programming physical address	6
<b>Start-up 7</b>	
Home page – Sensor values	7
Enter PIN	
<b>Menu – Settings..</b>	8
Language..	9
Display..	9
System..	10
Sensors..	11
Deactivate active sensor	11
Allocate new serial number to active sensor	12
<b>Menu – Switching channels..</b>	13
Select light threshold (brightness)	14
Select delay	15
Technical date	16
Service address/Hotline	16

## Basic safety instructions



**WARNING**

**Danger of death through electric shock or fire!**

➤ Installation should only be carried out by a professional electrician!

- The device is designed for installation on DIN top hat rails (in accordance with EN 60715); device conforms with EN 60669-1
- Professional installation of bus lines and commissioning of devices requires compliance with the provisions of EN 50428 for switches or similar installation equipment for use in building systems technology. Tampering with, or making modifications to, the device will invalidate the guarantee.

### Designated use


- The device registers the brightness via up to 3 external brightness sensors; the measured values are transmitted via the bus.
- Only use the device in enclosed, dry spaces; brightness sensors are installed in the open-air.

### Disposal

Dispose of device in environmentally sound manner

## Screen and keys

Screen display,  
e. g. sensor values



### **MENU**


- Activate screen
- Open menu
- Cancel menu
- ESC (1 step back)

Options  
are displayed

### **OK**

- Store selection
- Confirm selection

## Connection/installation



## Connection/installation

### WARNING




#### Danger of death through electric shock!

- Must only be installed by professional electrician!
- Disconnect power source!
- Cover or shield any adjacent live components.
- Ensure device cannot be switched again!
- Check power supply is disconnected!
- Earth and bypass!
- Observe SELV on data bus.


#### Connect cable

- Strip cable by 8 mm (max. 9 mm).
- Insert cable at 45° in the open terminal (2 cables per terminal position possible).
- With flexible wires only: To open the spring terminal, press screwdriver downwards.



## Bus connection

- Insert bus line in the front of the device.
- Ensure correct polarity.





## Program physical address

- Press button on front of the device.
  - The programming LED lights up.
  - Device is in program mode.

Start-up, diagnostics and configuration are handled by ETS 3 and 4 (KNX tool software).

## Start-up

The pages displayed depends on the programming by the ETS. Please refer to the Product Handbook for detailed functional descriptions (at [www.abb.com/knx](http://www.abb.com/knx)).





### Home page – Sensor values

If an external sensor is connected, the sensor value (lux value) appears on screen. The sensor LED flashes.

### Enter PIN

If **Access via PIN** is set on the ETS, the pin code (1000–9999) has to be entered before use.

- Enter the numbers with ▼ or ▲ and confirm with **OK**.




## Menu – Settings..

The **Settings** menu item can be used for setting the language, screen lighting or information on the device and sensors.


- Press **MENU** button.  
This brings up **Settings..**
- Confirm **settings..** by pressing **OK**.
- Use ▼ or ▲ to select language, display etc.
- Press **OK** to confirm or use ▼ or ▲ to select **Back**.






### Settings– Set language

- Use ▼ or ▲ to select **language**.
- Press **OK** to confirm.
- Use ▼ or ▲ to select **desired language**.



### Settings– Set display

- Use ▼ or ▲ to select **display**.
- Press **OK** to confirm.



## Settings – System..

- Use ▼ or ▲ to select **system**.
- Press **OK** to confirm.

The display shows

**Prog. mode** (Programming mode)


**PA** (Physical address)

**SW** (Software version)

**SN** (Serial number)

**FD** (Finishing date)

**HW** (Hardware)




## Settings – Sensors..

- Use ▼ or ▲ to select **sensors**.
- Confirm by pressing **OK**.



The **Sensors** menu item can be used to display the lux values for up to 3 connected sensors. The designation of the sensors can be changed using the ETS:

- active (serial number is displayed)
- inactive (sensor is not required)
- Error (sensor does send)



## Deactivate active sensor

- Use ▼ or ▲ to select the desired sensor.
- Confirm L1 sensor 1 (active) by pressing **OK**. This brings up serial numbers, lux value and **Deactivate**.
- Use ▼ or ▲ to select **Deactivate**.
- Confirm by pressing **OK**.



### Allocate new serial number to inactive sensor

- Use ▼ or ▲ to select **Next serial number**.
- Press **OK** to confirm.

The inactive sensor displays a new SN number.



- Use ▼ or ▲ to select **Allocate**.
- Press **OK** to confirm and, if reqd., select **Back** to leave menu.

If you want continue searching rather than accepting the sensor..

- Select **Next serial number**.
- Press **OK** to confirm.

## Menu – Switching channels..



The **Switching channels** menu item displays the status of the channel (ON, OFF, disabled/invalid):



- Press **MENU** button.

This brings up Settings.. and the **Switching channels..** etc.


- Use ▼ or ▲ **K1**: to select Switching channel 1.
- Press **OK** to confirm. It brings up **Status** (ON, OFF), **Light thresholds..** and **Next channel..**



## Select light thresholds (brightness)

The **Light thresholds** menu item can be used to set of the brightness of the relevant channel:

- Use ▼ or ▲ to select **Light thresholds**.
- Press **OK** to confirm.
- Use ▼ or ▲ to select lux value.
- Press **OK** to confirm.
- Use ▼ or ▲ to change lux value.
- Press **OK** to confirm desired lux value.



## Select delay

The **Delay** menu item can be used to set the delay time:

- Use ▼ or ▲ to select **Delay**.
- Press **OK** to confirm.
- Use ▼ or ▲ to select **Exceed** or **Underrun**.
- Press **OK** to confirm selection.
- Use ▼ or ▲ to change the delay values.
- Press **OK** to select desired delay value.

## Technical data

- Operating voltage: 110–240 V~, +10 %/-15 %
  - Frequency: 50–60 Hz
  - Power consumption: typically 1 W
  - Standby min.: 0.8 W
  - Data output: Safety Extra Low Voltage (SELV)
  - Permissible ambient temperature:
    - 5 °C ... +45 °C
    - 40 °C ... +70 °C (sensor)
  - On/Off switching delay: 0–20 min
  - Brightness measuring range: 1–100000
  - Protection class: II subject to correct installation
  - Protection rating: IP 20 in accordance with EN 60529
  - Pollution level: 2
  - Max. cable cross section: 2.5 mm<sup>2</sup>
  - Operating voltage KNX: bus voltage ≤10 mA
  - Cable length: 100 m (YCYM 2 x 2 x 0.8 mm  
2 pairs for DATA bus)  
50 m (YCYM 2 x 2 x 0.8 mm
- 1 pair each for KNX and DATA bus)
- Max. number of connectable brightness sensors for HS/S4.2.1 at DATA bus: 3

### Service address

#### ABB STOTZ-KONTAKT GmbH

Eppelheimer Straße 82

69123 Heidelberg

Germany

Tel. +49 6221 701-434

Fax +49 6221 701-724

[www.abb.com/knx](http://www.abb.com/knx)